

Government of Bihar
Public Health Engineering Department
Water Quality Test Report

District Name: Gopalganj

Division Name: P.H.Division Gopalganj

Sample Code GPJ/26/27/01

SL No.	Block	Panchayat	Village	Ward No.	Location of Source	Parameters													Date of Testing	Remarks	
						pH	Turbidity (NTU)	EC	TDS (mg/l)	Total Hardness (mg/l)	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Total Alkalinity (mg/l)	Iron (mg/l)	Nitrate (mg/l)	Sulphate (mg/l)	Fluoride (mg/l)			Total Coll
1	Panchdewari	Majhwaliya	Nahar Tola	13	Disha Public School	7.31	0.1	667	433	292	71	32	35	350	0.29	0.54	128	0.12	Absent	18/07/2026	
Desirable Limit*						6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	-		
Permissible Limit* in absence of alternate source (IS 10500:2012 - 2nd revision & Rev 2015)						NR	5.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	**		


Chemist / Lab Asst
DLL, P.H. Division, Gopalganj


P.H.Division, Gopalganj


Executive Engineer
P.H.Division, Gopalganj